

Confirmation

LEED

On 26 October, Eurofins Product Testing A/S received a sample of Cast In with the product name:

CFS-CID 160

supplied by

Hilti Entwicklungsgesellschaft GmbH

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and CDPH testing standards (See test report no. 392-2015-00336801_H).

The test results of the tested sample indicate that the product qualifies for LEED v4 and LEED 2009 specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of CDPH-IAQ (California Department of Public Health, Feb 2010); and a TVOC below 0.5 mg/m³ in both office and class room.

26 November 2015



Lise L. Clement
Chemist



Janne R. Norup
Chemist