cPVC pipes Through Slab

APPLICATION:

CP638: MP-RF-M-05

## **INFORMATION:**

- Not to scale
- All units are in millimetres
- Tested according EN 1366-3
- Classification Report 23003B

**CP 638 Mortar + CP-645** 

DATE


01

ID:

05/2025

Fire Rating up to El 180

**Page 1/1** 




## Notes:

 All gaps around services and coated board edges filled with Hilti Firestop Acrylic Sealant CFS-S ACR

Copper, steel and stainless steel pipes insulated with combustible insulation Kingspan
Kooltherm

Kooltheitti				
Pipe brand & type	Diameter	Wall thickness	Fire rating in mixed opening	
Viking BlazeMaster	26.7 to 60.3	2.0 to 4.5	EI 180-U/C	
Spears FlameGuard	26.7 to 60.3	2.25 to 4.7	EI 180-U/C	



Spacing overview for mixed seals					
Description	Shortcut	Distance			
To seal edge	b	≥ 0 mm			
To other pipes with CP-645 in linear arragement	C <sub>1</sub>	≥ 0 mm			
To any other services	C <sub>2</sub>	≥ 100 mm			

Maximum opening size without additional support: 2000 x 1800 mm or reduced width, with up-to 10m length. See classification report for further details.

 All services are to be correctly and adequately supported to prevent collapse and distortion Hilti (Gt. Britain) Limited | No 1, Circle Square | 3 Symphony Park | Manchester | M1 7FS

Freephone: 0800 886 100 | Website: www.hilti.co.uk

<sup>1.</sup> The application limits on this detail are for guidance purposes only. For more detailed information based on the full range of available test results please contact the Hilti Technical Advisory Service

<sup>2.</sup> The product and application has been assessed as a minimum to the BS 476 standard. It may have additional European and worldwide testing. Please contact Hill for further information 3. All installations should be carried out in accordance with Hilli's installation instructions and by competent & experienced installers using Hilli branded products.

4. All services are to be correctly and adequately supported to prevent collapse and distortion.